

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 60118838

Blatt *Page*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*
0001--21269626 001

Ausstellungsdatum
18.04.2017

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Enfros Technologies Pvt. Ltd.
Plot No 109, 1st Phase
Harohalli Industrial Area
Kanakapura Taluk
Bangalore 562112
India

Fertigungsstätte *Manufacturing Plant*

Enfros Technologies Pvt. Ltd.
Plot No 109, 1st Phase
Harohalli Industrial Area
Kanakapura Taluk
Bangalore 562112
India

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

IEC 61215:2005
EN 61215:2005
IEC 61730-1:2004+A1+A2
IEC 61730-2:2004+A1
EN 61730-1:2007+A1+A2
EN 61730-2:2007+A1

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

PV-Module

Type:

with 6" poly cells

EFS24xxxMF72 (xxx = 275-340 in steps of 1 with 72 cells)
EFS20xxxMF60 (xxx = 230-285 in steps of 1 with 60 cells)
EFS18xxxMF54 (xxx = 210-255 in steps of 1 with 54 cells)
EFS16xxxMF48 (xxx = 185-225 in steps of 1 with 48 cells)
EFS12xxxMF36 (xxx = 140-170 in steps of 1 with 36 cells)

with 6" poly cut cells

EFS24xxxMC72 (xxx = 135-275 in steps of 1 with 72 cells)
EFS12xxxMC36 (xxx = 053-136 in steps of 1 with 36 cells)
EFS12xxxMC36 (xxx = 005-052 in steps of 1 with 36 cells)
EFS06xxxMC18 (xxx = 003-005 in steps of 1 with 18 cells)

xxx represent output power in Wp

Remarks:

The above listed PV modules fulfil the requirements of Application Class A (Class II acc. to IEC 61140). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1500 VDC.

The above listed PV modules fulfil the requirements of fire rating class C.

continued on page 2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Dipl.-Ing. M. Adrian

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 60118838


Blatt *Page*
0002

<i>Ihr Zeichen Client Reference</i>	<i>Unser Zeichen Our Reference</i>	<i>Ausstellungsdatum Date of Issue</i>
	0001--21269626 001	18.04.2017 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Enfros Technologies Pvt. Ltd.
Plot No 109, 1st Phase
Harohalli Industrial Area
Kanakapura Taluk
Bangalore 562112
India

Fertigungsstätte *Manufacturing Plant*
Enfros Technologies Pvt. Ltd.
Plot No 109, 1st Phase
Harohalli Industrial Area
Kanakapura Taluk
Bangalore 562112
India

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

IEC 61215:2005
EN 61215:2005
IEC 61730-1:2004+A1+A2
IEC 61730-2:2004+A1
EN 61730-1:2007+A1+A2
EN 61730-2:2007+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Module

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. The certificate has a validity of 5 years counting from date of issue.

*Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.*

Zertifizierungsstelle



Dipl.-Ing. M. Adrian

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 <http://www.tuv.com/safety>